

<b>Owner:</b> Kroger 40393 Grand River Avenue Novi, MI 48375	<b>Project:</b> <b>Project #:</b> 15100 Silver Parkway Fenton, MI 48430	Fenton, MI - TBD 018-00416-01
<b>Architect:</b> Jeffery A. Scott & Associates 32316 Grand River Avenue Suite 200 Farmington, MI 48336	<b>Response Needed By:</b> <b>Request:</b> <b>Review:</b> <b>Response:</b>	Original: 05/14/2025 Original: 05/20/2025 Original: 05/23/2025
<b>Contractor:</b> Tony And Sons, Inc. 4049 Beach Dr Orchard Lake, MI 48324	<b>Submitted By:</b>	Jon Buddingh

Contractor Request

Request Submitted By: Jon Buddingh 05/14/2025

Request:	The existing beam that runs the length of the store in the old "farm fresh" portion of the store does not have a cut through on A3.2. The existing beam is wider than 8" as the new wall is specified to be installed, however the existing beam that the wall is to be installed under is wider than 8". Are we to box around the existing beam or are we to frame the wall up to the beam and "fill in" the 2-3" gap above the beam and just paint the existing beam?
Suggestion:	Please advise. We advise to fram and drywall under the existing beam, fill in the 2-3" gap above the beam and the and then paint the existing beam.

ATTACHMENTS

File Name	Date / Time	Type	By
IMG_3119.jpg	5/14/2025 10:18:00 AM	.jpg	JB
IMG_3120.jpg	5/14/2025 10:18:00 AM	.jpg	JB
IMG_3121.jpg	5/14/2025 10:18:00 AM	.jpg	JB

Response

Response By: Matt Andrus 05/23/2025

Response:	Please frame up to the beam, fill the gap above the beam, and paint the existing beam. There needs to be a separation between the sales floor and the back room.
-----------	--