



- ① RE-BALANCE EXISTING SUPPLY AIR DIFFUSERS, AS INDICATED.
- ② RE-INSTALL EXISTING S.A. DIFFUSERS AND RE-CONNECT TO EXISTING S.A. DUCT WORK AS NECESSARY TO SERVE NEW OFFICES. BALANCE AS INDICATED.
- ③ PROVIDE AND INSTALL NEW S.A. DIFFUSER FOR NEW STORAGE. MATCH EXISTING COLOR AND STYLE. BALANCE AS INDICATED.
- ④ PROVIDE (BY KROGER) AND INSTALL (BY MECHANICAL CONTRACTOR) NEW SPLIT SYSTEM AC UNIT FOR EGR ABOVE C/W NEW REFRIGERANT PIPING, CURB, ROOF PENETRATION AND CONTROLS.
PROVIDE CONDENSATE PUMP.

D1 DISCONNECT AND REMOVE EXISTING SUPPLY AIR DIFFUSER. CAP DUCTWORK BRANCH AT MAIN.

D2 DISCONNECT AND REMOVE EXISTING SUPPLY AIR DIFFUSERS. CAP DUCTWORK BRANCH. CLEAN DIFFUSERS AND PREPARE FOR RE-INSTALLATION IN NEW CEILING GRID.

1P EXTEND NEW CONDENSATE LINE FROM NEW AC UNIT TO NEAREST SANITARY LINE. VERIFY LOCATION ON SITE.

D1 DISCONNECT AND REMOVE EXISTING SINK. CUT AND CAP CW, HW AND VENT LINES IN CEILING SPACE. CAP SAN DRAIN BELOW FLOOR AS PER PSD 99 DETAIL.

- 1) SPLIT SYSTEM USES PURON (R-410A) REFRIGERANT.
- 2) SPLIT SYSTEM PROVIDED BY KROGER AND INSTALLED BY GC/MC.
- 3) CONTACT MITSUBISHI ELECTRIC: STEVE NIEZUR 810 956 2284

1) GC/HVAC CONTRACTOR TO SUPPLY ALL NEW DIFFUSERS. VERIFY TYPES, INSTALL MODE, COLOR, ACCESSORIES, ETC PRIOR TO ORDER.



BIDS & PERMITS OWNER REVIEW		04-10-2012 03-28-2012
issued for:		
PROPOSED MINOR REMODEL FOR:		
		
STORE NO. D-447		
23101 JOHN R ROAD HAZEL PARK, MICHIGAN 48030		
THE KROGER CO.		
		
jeffery a. scott architects p.c.		
32316 grand river ave. suite 200 farmington, michigan 48336-3261 (248) 476-8800 fax (248) 476-8833		
HVAC/PLUMBING PLAN		
project no.	sheet no.	
1211	MP-1	